

Model: SDP-006 Dual Programmable Timer

The SmartSwitch Dual Programmable Timer is a Universal Dual Programmable Timer.

The SDP-006 has a programmable ON time and a programmable OFF time, both these timers can be individually programmed from between 1 second and 365 days.

The On and Off Times are completely independent e.g. you can set the On Time for 10 seconds and the Off Time for 10 days or vice versa.

Once the input is triggered the relay will close and the unit will run timer 1 then timer 2. If placed in continuous loop mode (see Fig 2.3) the unit will run this timing sequence forever.

Just program the On Time required, the Off Time required and which cycle to start in. Connect the Input connection (Fig 2), connect the Power and Relay (Fig 3) and it's ready to go.



Time's:

Programmable On and Off Time Options (Actuate to $\pm 0.1\%$)

Option 1 sets seconds from 1 to 240

Option 2 sets minutes from 1 to 240

Option 3 sets hours from 1 to 240

Option 4 sets days from 1 to 240

The On and Off Times are completely independent e.g. you can set the On Time for 10 seconds and the Off Time for 10 days or vice versa.

Inputs:

Input Trigger Option 1 (Use Input One)

By using Input One the device is triggered by a switch press and release. The timer will complete the first time cycle, then the second time cycle, then halt waiting for another trigger. When the timing cycle is running, a second press will cancel the cycle (reset).

Input Trigger Option 2 (Use Input Two)

By using Input Two the device is triggered by a switch press. The timer will complete the first time cycle, then the second time cycle then halt waiting for another trigger. In this mode Input One can be used to cancel the cycle (reset).

Continuous Loop Mode

By connecting Input One and Two together the device is triggered by a switch closure between Common and Input1 and 2. The timer will complete the first time cycle, then the second time cycle and continue this loop until the inputs are opened.

Programming the Device:

ENSURE INPUT TWO IS NOT IN CONTINUOUS LOOP MODE

Step 1 – Placing the unit in program mode (see *Fig 3* for button layout). After wiring and applying power, hold the Set button down for 3 seconds. The LED will give five quick flashes indicating you have entered program mode.

Step 2 – Setting up seconds, minutes, hours or days (pause between each press and wait for the LED to flash).

Press the x1 button:

- Once for seconds (the LED will flash once indicating second mode)
- Twice for minutes (the LED will flash twice indicating minute mode)
- Three times for hours (the LED will flash three times indicating hour mode)
- Four times for days (the LED will flash four times indicating day mode - 1 day = 24 hours)

A fifth press will cancel and start back at *Step 2* (the LED will give four quick flashes to indicate this).

Once the above time mode is selected, press the Set button again. The LED will flash once to indicate this has been set.

Step 3 – Setting the time – Next press any combination of the x1 or x10 buttons to select the time required. The LED will flash with each press indicating a valid key press.

For example:

Time required = 50 (seconds, minutes, hours or days) you can either press the x1 button 50 times or press the x10 button 5 times.

Time required = 56 (seconds, minutes, hours or days) press the x10 button 5 times and the x1 button 6 times.

Step 4 – Setting – Once the above time is selected press the Set button. The LED will flash once to indicate this.

Step 5 – Setting On or Off time - Press either the x1 or the x10 button. The x1 button will set the On Time and the x10 button will set the Off Time. The LED will give five quick flashes indicating you have now programmed the device and left program mode.

Please Note: Steps 1 to 5 have to be performed for both the On and Off Times

Programming the Start Timer – Setting the timer to start in the On or Off mode.


Step 1 – Hold the x10 button down for 3 seconds. The LED will flash five times to indicate this program mode.

Step 2 – Press the x1 button to start with the On Timer or press the x10 button to start with the Off Timer. The LED will flash once indicating a valid key press.

Step 3 – Press the Set button. The LED will give five quick flashes indicating you have now programmed the device and left program mode.

The device is now programmed and ready for use. If you make an error or want to cancel the programming operation simply turn the power off, wait a few seconds power the timer back on and start again from Step 1.


Programming Flow Chart



Input Wiring (Fig 2)

The triggering switch can be connected to s/w com and Input 1 or Input 2 (Fig 2.1 a & b).
Or from any existing switch (Fig 2.2) (max 37v), provided it has a common negative to the Timer.
Or the device can be placed in continuous loop as per (Fig 2.3) (switch not supplied).

Fig 2.1a



One shot mode






Fig 2.1b



One shot mode



Or

Fig 2.2






Fig 2.3



Continuous loop mode

Connections

Fig 3



Electrical Specifications

Supply Voltage =	12 or 24 Volts DC (Auto-Sensing)
Current Draw =	12 mA @ 12 Volts
Output Load =	3 amps 125 VAC (Inductive)
Input Trigger =	5 ~ 37 Volts DC
Input =	Voltage and EMI Protected
Data Retention =	40 years (without power)

This device should be fuse protected (5 Amp maximum) and mounted in a dry area.

©

All technologies, design and Intellectual property is owned by
Smart Switch Technologies Ltd
Po Box 272, Waikanae. NZ
Phone 0064-4-293-4201 Fax 0064-4-293-4201
Email: info@smartswitch.co.nz Web: www.smartswitch.co.nz